

BOIL WATER NOTICE RESCINDED

The Topaz Ranch Estates GID WATER SYSTEM

PWS I.D. # NV0000239

The precautionary “Boil Water Notice” issued to the Topaz Ranch Estates GID WATER SYSTEM on 7-21-26 affecting Topaz Ranch Dr between Boulder and Granite. is hereby rescinded. Bacteriological test results indicate that E. coli and other coliform bacteria are *not* present in the system. The test results are as follows:

Sample Date	Number of Samples	Results
7/23/26_____	2	Absent
7/24/26_____	2	Absent

Signed Jeff Dines

Date 7/27/2026